

## **Tisa, Kimberly**

---

**From:** Tisa, Kimberly  
**Sent:** Thursday, August 14, 2014 8:12 AM  
**To:** Robert May  
**Cc:** Tisa, Kimberly  
**Subject:** FW: Westport Middle School  
**Attachments:** [Untitled].pdf

Bob:

Attached is the air data table I discussed with you this morning for the Westport Middle School. As you can see, many rooms have not been sampled on an annual basis as was proposed by the school.

I also do not have all laboratory reports for all samples. The April 2013 Report I received contained a CD; however, the only laboratory reports I found were for samples collected in January 2012; April 2012; and June 2012.

Per I discussion, please ensure I have all air sample results, including pre- and post-abatement samples. I also need the laboratory reports, which can be provided on a CD-ROM. You also mentioned a feasibility report that contains more PCB data as well as an evaluation of remedial alternatives with costs, which you will get to me. I appreciate this.

*Non Responsive*

Should you have any questions, please feel free to call me.

Kimberly N. Tisa, PCB Coordinator (OSRR07-2) USEPA  
5 Post Office Square, Suite 100  
Boston, MA 02109-3912

(o) 617.918.1527  
(f) 617.918-0527

-----Original Message-----

From: Tisa, Kimberly [mailto:Tisa.Kimberly@epa.gov]  
Sent: Thursday, August 14, 2014 8:02 AM  
To: Tisa, Kimberly  
Subject:

Please open the attached document. This document was digitally sent to you using an HP Digital Sending device.



Room	Testing date/ PCB								
	1/23/2012	3/29/2012							
Kitchen				160			120		
Kitchen office					40	160		100	
Kitchen locker		42				160			
Cafe side A (office)				96			100		
Cafe side B (283)				110			90		
Media Center				110 & 93			130		
Gym				37			26 & 9.5		
Boy's Locker room				64			24		
Girl's Locker room				58			22		
Room 101			58			80			
Room 102		100							
Room 103	2.3				19				
Room 117	prior 83								
Room 118		150							
Room 212 (Staff dining)					290	300		110	
Room 235- (office)						90		83	
Room 249 Conf			400		140	95		83	
Room 250/251 Lab B		340			100				
Room 255 (office)					600				
Room 254						110			
Room 256		220							
Room 257		190							
Room 258 (Lab A)	140								
Room 259		190				110			
Room 263 (SAC)				200			88		
Room 280			150			210			
Auditorium	18								
Cust. dock			180			89			
Storage/dock			160			140			
Main Office		100							
Coffee Room (file room)			130			120			
Room 227 (office)	110								
Conf room near nurse	100 (Jan.2011)								
Nurse's Office					100			130	
Nurse's Back room								190	
Coffee Room near Nurse			210					190	
Guidance 2					530	700		300	
Room 221 (Guidance)			160					250	

Room 220 (Prin)					250 (150 12/26/12)			230	
Room 219 (A/P)					250				
Room 218 (Ex sec)		240							
	1/23/2012	3/29/2012	6/9/2012	9/28/2012	12/21/2012	6/15/2013	10/25/2013	1/17/2014	4/2014
<b>Classrooms</b>									
Room 104			97			55 & 69			
Room 105		6							
Room 106	39								
Room 107				78			98		
Room 108				100			94		
Room 110		66							
Room 112					63			28 & 48	
Room 116					83			70	
Room 120				110			130		
Room 121	57				49			58	
Room 122				100			70		
Room 124					24				
Room 125		170							
Room 154					26			26	
Room 163					42			33	
Room 164	22								
Room 166				49			89		
Room 167					78			48	
Room 168		160							
Room 171					180			84	
Room 172			69			47			
Room 175	21								
Room 237		120							
Room 238			110	170					
Room 239	160				230			110	
Room 241	81								
Room 242		110							
Room 264		160						120	
Room 268			250 & 240		110	140			
Room 274	55								
Room 275				63			48		
Room 277	22								
Room 278							110		
Room 279		150			110			55	
Room 283				22			210		

Room 24 (Music)								110 (30 on 12/26/12)				67	
-----------------	--	--	--	--	--	--	--	----------------------	--	--	--	----	--





**FUSS & O'NEILL**  
EnviroScience, LLC

**Table 2**  
**Second Quarter Post Remediation PCB Air Sample Results Summary**  
**Collected on: January 16, 2014**  
Westport Middle School  
400 Old County Road  
Westport, MA

Location	Last Result Nanograms/m <sup>3</sup>	Date	Current Result Nanograms/m <sup>3</sup>	Date	EPA Threshold Nanograms/m <sup>3</sup>
Kitchen Office	40	12/21/2012	100	1/16/2014	300
Room 212 (Staff Dining Room)	290	12/21/2012	110	1/16/2014	300
Room 220	250	12/21/2012	230	1/16/2014	300
Room 220	150	12/26/2012	230	1/16/2014	300
Room 221	<b>330</b>	3/29/2012	250	1/16/2014	300
Room 239	230	12/21/2012	110	1/16/2014	300
Room 249	140	12/21/2012	83	1/16/2014	300
Guidance 2	<b>530</b>	10/25/2013	300	1/16/2014	300
File Room Adjacent to Nurses	NA	NA	190	1/16/2014	300
Nurse's Office	170	10/25/2013	130	1/16/2014	300
Nurse's Back Room	NA	NA	190	1/16/2014	300
Room 24	110	12/21/2012	67	1/16/2014	300
Room 24	30	12/26/2012	67	1/16/2014	300
Room 235	90	6/15/2013	83	1/16/2014	300
Room 279	110	12/21/2012	55	1/16/2014	300
Room 279	64	12/26/2012	55	1/16/2014	300
Room 279	110	12/21/2012	55	1/16/2014	300
Room 264	71	3/19/2013	120	1/16/2014	300
Room 121	49	12/21/2012	58	1/16/2014	300
Room 116	83	12/21/2012	70	1/16/2014	300
Room 112	63	12/21/2012	28 48 (Duplicate)	1/16/2014	300
Room 103	19	12/21/2012		1/16/2014	300
Room 171	180	12/21/2012	84	1/16/2014	300
Room 167	78	12/21/2012	48	1/16/2014	300
Room 163	42	12/21/2012	33	1/16/2014	300
Room 154	41 26 (Duplicate)	12/21/2012	26	1/16/2014	300